

Measurements

General Information

Customer		Measurements	
Company name	SCS Limited	Date	22/12/2020 09:31
Contact Person	Hennie Wentzel	Measuring site	Barnehurst Golf
Street	Mayplace Road East	Fuel	Natural Gas
City	Kent	O ₂ ref	3.0 %
Email	hennie@scservicesltd.co.uk	CO ₂ max	11.9 %
Phone	07711826859		

Device Information t300

Firmware	1.09.5212	Software version	11.6.0.10417
Device name	testo 300		
Device identification number	TT3662117020NEU1120		
Serial number	62117020		
Smoke pump number			
Last service date	06.11.20		

Flue Gas - 22/12/2020 09:26

AT	31.2 °C	NOx	36 ppm
FT	140.4 °C	ExAir	47.8 %
O ₂	6.8 %	Draught	-0.088 mbar
CO	26 ppm	uCO	38 ppm
CO ₂	8.05 %	AT	31.2 °C
Ratio	0.0003	AmbCO	--- ppm
Effg	84.3 %	Pump	0.60 l/min
Effn	93.0 %	Dew Pt	55.7 °C
NO	34 ppm		

Flue Gas - 22/12/2020 09:27

AT	31.3 °C	NOx	46 ppm
FT	175.7 °C	ExAir	33.9 %
O ₂	5.3 %	Draught	-0.105 mbar
CO	50 ppm	uCO	67 ppm
CO ₂	8.89 %	AT	31.3 °C
Ratio	0.0006	AmbCO	--- ppm
AT	31.3 °C	NOx	46 ppm
Effg	83.1 %	Pump	0.60 l/min
Effn	91.6 %	Dew Pt	57.1 °C
NO	44 ppm		