

Measurements

General Information

Customer		Measurements	
Company name	SCS Limited	Date	22/12/2020 09:41
Contact Person	Hennie Wentzel	Measuring site	Barnehurst Golf
Street	Mayplace Road East	Fuel	Natural Gas
City	Kent	O ₂ ref	3.0 %
Email	hennie@scservicesltd.co.uk	CO ₂ max	11.9 %
Phone	07711826859		

Device Information t300

Firmware	1.09.5212	Software version	11.6.0.10417
Device name	testo 300		
Device identification number	TT3662117020NEU1120		
Serial number	62117020		
Smoke pump number			
Last service date	06.11.20		

Flue Gas - 22/12/2020 09:37

AT	31.9 °C	NOx	44 ppm
FT	155.6 °C	ExAir	31.7 %
O ₂	5.1 %	Draught	-0.131 mbar
CO	14 ppm	uCO	18 ppm
CO ₂	9.04 %	AT	31.9 °C
Ratio	0.0002	AmbCO	--- ppm
Effg	84.2 %	Pump	0.60 l/min
Effn	92.8 %	Dew Pt	57.5 °C
NO	42 ppm		

Flue Gas - 22/12/2020 09:38

AT	31.9 °C	NOx	51 ppm
FT	172.3 °C	ExAir	28.3 %
O ₂	4.6 %	Draught	-0.145 mbar
CO	10 ppm	uCO	13 ppm
CO ₂	9.28 %	AT	31.9 °C
Ratio	0.0001	AmbCO	--- ppm
AT	31.9 °C	NOx	51 ppm
Effg	83.5 %	Pump	0.60 l/min
Effn	92.1 %	Dew Pt	57.8 °C
NO	49 ppm		

